



! NOTE !

*Please ensure that neutrals are derived from the same supply to prevent spurious MCB/RCD trips.

! NOTE !

This wiring diagram should be read in conjunction with the Grant Aeraona Smart Controls installation instructions and system schematic HPCS-P003SR32.

Project Title: Smart Controls
Installation Pack P
S-Plan Plus type system with Low Loss Header
Radiator Upstairs - UFH Downstairs
HW priority & Legionella Protection
from wiring centre (System schematic)

Drawing Set: Aeraona Smart Controls
Wiring Schematics

Status: Pending of approval

Rev Date: 21/06/24 | Drawn By: AC&DB

Frankland Road, Blagrove Industrial Estate, Swindon, SN5 8YG, tel: 01380 736920

Dwg. No:
HPCS-P003ER32

Revision: 0.7

Checked By: NS

Scale: NTS
Paper Size: A3

