Product fiche relating to: The Eco Design for Energy Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019

Air Source Heat Pumps

 Grant Engineering (UK) Ltd

 Frankland Road, Blagrove, Swindon, Wiltshire SN5 8YG

 t: +44 (0)1380 736920
 f: +44 (0)1380 736991

 e: info@grantuk.com
 w: www.grantuk.com



Indoor Unit: None	Models:	Outdoor Unit:	Aerona HPIDR2904
		Indoor Unit:	None
AIr-to-water neat pump Yes	Air-to-water heat pump		Yes
Brine-to-water heat pump No	Brine-to-water heat pump		No
Low temperature heat pump Yes	Low temperature heat pump		Yes
Equipped with a supplementary heater No	Equipped with a supplementary heater		No
Heat Pump Combination Heater No	Heat Pump Combination Heater		No
Parameters shall be declared for low-temperature applications	Parameters shall be declared for		low-temperature applications
Parameters shall be declared for Average Climate Conditions	Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	4.09	kW	Seasonal space heating energy efficiency	ηs	200	%
Declared capacity for heating fo Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
Ti = -7°C	Pdh	3.78	kW	Tj = -7°C	COPd	3.57	
Degradation co-efficient (**)	Cdh	0.90	-				
$T_j = +2^{\circ}C$	Pdh	2.40	kW	Tj = +2°C	COPd	5.19	
Degradation co-efficient (**)	Cdh	0.90	-				
$Ti = +7^{\circ}C$	Pdh	1.70	kW	Tj = +7°C	COPd	6.47	
Degradation co-efficient (**)	Cdh	0.90	-				
$T_j = +12^{\circ}C$	Pdh	1.35	kW	Tj = +12°C	COPd	6.23	
Degradation co-efficient (**)	Cdh	0.90	-				
Ti = bivalent temperature	Pdh	3.98	kW	Tj = bivalent temperature	COPd	3.29	
Tj = operation limit temperature	Pdh	3.77	kW	Tj = operation limit temperature	COPd	3.05	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-8		Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	other than	active mo	de	Supplementary Heater			
Off Mode	POFF	0.007	kW	Rate heat output	Psup	0.300	kW
Thermostat-off mode	Рто	0.021	kW				
Standby mode	PsB	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	Рск	0.020	kW				
Other items	Meniati		1	Detect cirflere rete		0000	
Capacity control	Variable		dBA	Rated airflow rate, outdoors	-	2300	m³/h
Sound power level indoors/outdoors	L _{WA}	/47	aвя				
Annual Energy consumption	Q _{HE}	1664	kWh				
For heat pump combination heater				Water heating energy efficiency	ηwh		%
Declared load profile		NA					
Daily electricity consumption	Qelec		kW/h				
Annual electricity consumption	AEC		kW/h				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Models:	Outdoor Unit:	Aerona HPIDR2904
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		No
Low temperature heat pump		No
Equipped with a supplementary heater		No
Heat Pump Combination Heater		No
Parameters shall be declared for		Medium-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Uni
	6			Seasonal space heating		140	
Rated Heat Output (*)	Prated	4.36	kW	energy efficiency	ηs	146	%
Declared capacity for heating fo Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
$Ti = -7^{\circ}C$	Pdh	3.93	kW	$Tj = -7^{\circ}C$	COPd	2.48	
Degradation co-efficient (**)	Cdh	0.90	-	1] = -7 0		2.40	
$Ti = +2^{\circ}C$	Pdh	2.34	kW	Tj = +2°C	COPd	3.73	
Degradation co-efficient (**)	Cdh	0.90	-	1) = +2 0		5.75	
$Tj = +7^{\circ}C$	Pdh	1.92	kW	Tj = +7°C	COPd	4.69	
Degradation co-efficient (**)	Cdh	0.90	-	1)-110		4.00	
$T_i = +12^{\circ}C$	Pdh	1.25	kW	Tj = +12°C	COPd	6.06	
Degradation co-efficient (**)	Cdh	0.90	-	1] = 112 0		0.00	
$T_j = bivalent temperature$	Pdh	3.927	kW	Tj = bivalent temperature	COPd	2.32	
$T_j = operation limit$							
temperature	Pdh	3.80	kW	Tj = operation limit temperature	COPd	2.21	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-8	°C	Operation limit temperature	TOL	-10	°C
i				Heating water operating limit temperature	WTOL	60	°C
					I		
Power consumption in modes	other than	active mo	de	Supplementary Heater			
Off Mode	Poff	0.007	kW	Rate heat output	Psup	0.520	kW
Thermostat-off mode	Рто	0.021	kW				
Standby mode	Psb	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	Рск	0.020	kW				
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	2300	m³/h
Sound power level indoors/outdoors	L _{WA}	/48	dBA				
Annual Energy consumption	Q _{HE}	2411	kWh				
For heat pump combination heater			1	Water heating energy efficiency	ηwh	132.1	%
Declared load profile	-	Large	-	Reference Hot Water		54.98	°C
Daily electricity consumption	Qelec	3.75	kWh				
Annual electricity consumption	AEC	774.8	kWh/a				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer.

Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it still remains contaminated by the refrigerant.

Neil Sawers Technical Manager

Grant heat pump fiche HPR2904 V1.6 15/01/2025

