Product fiche relating to: The Eco Design for Energy Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019

Air Source Heat Pumps

 Grant Engineering (UK) Ltd

 Frankland Road, Blagrove, Swindon, Wiltshire SN5 8YG

 t: +44 (0)1380 736920
 f: +44 (0)1380 736991

 e: info@grantuk.com
 w: www.grantuk.com



Models:	Outdoor Unit:	Aerona HPR29065
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		No
Low temperature heat pump		Yes
Equipped with a supplementary heater		No
Heat Pump Combination Heater		No
Parameters shall be declared for		low-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	6.50	kW	Seasonal space heating energy efficiency	ηs	203	%
Declared capacity for heating for Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
Ti = -7°C	Pdh	6.33	kW	Tj = -7°C	COPd	3.25	,
Degradation co-efficient (**)	Cdh	0.90	-				
$Ti = +2^{\circ}C$	Pdh	4.03	kW	Tj = +2°C	COPd	5.22	
Degradation co-efficient (**)	Cdh	0.90	-	.,			
$Ti = +7^{\circ}C$	Pdh	2.74	kW	Tj = +7°C	COPd	6.85	
Degradation co-efficient (**)	Cdh	0.04	-				
$Ti = +12^{\circ}C$	Pdh	2.24	kW	Tj = +12°C	COPd	8.07	
Degradation co-efficient (**)	Cdh	0.90	-				
$T_j = bivalent temperature$	Pdh	6.18	kW	Tj = bivalent temperature	COPd	2.91	
Tj = operation limit temperature	Pdh	5.99	kW	Tj = operation limit temperature	COPd	2.82	
$T_j = -15^{\circ}C$ (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-9		Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	other than	active mo	de	Supplementary Heater			
Off Mode	POFF	0.007	kW	Rate heat output	Psup	0.48	kW
Thermostat-off mode	Рто	0.025	kW		i sup	0.10	
Standby mode	PsB	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	Рск	0.020	kW	Type of energy input			
Other items			r				0.11
Capacity control	Variable			Rated airflow rate, outdoors	-	2650	m³/h
Sound power level indoors/outdoors	L _{WA}	/51	dBA				
Annual Energy consumption	Q _{HE}	2603	kWh				
For heat pump combination heater				Water heating energy efficiency	ηwh		%
Declared load profile		NA					
Daily electricity consumption	Qelec		kW/h				
Annual electricity consumption	AEC		kW/h				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Models:	Outdoor Unit:	Aerona HPR29065
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		No
Low temperature heat pump		No
Equipped with a supplementary heater		No
Heat Pump Combination Heater		No
Parameters shall be declared for		Medium-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Uni
				Seasonal space heating			
Rated Heat Output (*)	Prated	6.50	kW	energy efficiency	ηs	145	%
					· ·		
Declared capacity for heating for Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
$Ti = -7^{\circ}C$	Pdh	5.98	kW	Tj = -7°C	COPd	2.33	
Degradation co-efficient (**)	Cdh	0.90	-	IJ = -7 C	COFU	2.33	
$T_i = +2^{\circ}C$	Pdh	3.99	kW	Tj = +2°C	COPd	3.77	
Degradation co-efficient (**)	Cdh	0.90		1] = +2 0		5.77	
$T_i = +7^{\circ}C$	Pdh	2.75	kW	Tj = +7°C	COPd	4.74	
Degradation co-efficient (**)	Cdh	0.90	KVV	1] = +7 0	COFU	4.74	
$Tj = +12^{\circ}C$	Pdh	2.41	- kW	Tj = +12°C	COPd	6.17	
Degradation co-efficient (**)	Cdh	0.90	KVV	1] = +12 0	COFU	0.17	
$T_j = bivalent temperature$	Pdh	6.09	- kW	Ti – bivalant tomporatura	COPd	2.09	
Tj = operation limit	Full	0.09	KVV	Tj = bivalent temperature		2.09	-
temperature	Pdh	5.65	kW	Tj = operation limit temperature	COPd	1.97	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-8	°C	Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	othor than	aativa ma	do	Supplementary Heater			_
Off Mode	POFF	0.007	kW	Supplementary Heater Rate heat output	Psup	0.790	kW
Thermostat-off mode	Рогг	0.007	kW		rsup	0.790	KVV
Standby mode	PIO	0.025	kW	Type of operative		Electric	
Crankcase heater mode	Рѕв Рск	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	РСК	0.020	KVV				
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	2650	m³/h
Sound power level indoors/outdoors	L _{WA}	/52	dBA				
Annual Energy consumption	Q _{HE}	3633	kWh				
For heat pump combination heater				Water heating energy efficiency	ŋwh	129.3	%
Declared load profile	-	Large	-	Reference Hot Water	1.1	55.53	°Ĉ
Daily electricity consumption	Qelec	3.83	kWh			00.00	
Annual electricity consumption	AEC	791.64	kWh/a				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer.

Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it still remains contaminated by the refrigerant.

Neil Sawers Technical Manager

Grant heat pump fiche HPR29065 V1.6 15/01/2025

