Product fiche relating to: The Eco Design for Energy Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019

Air Source Heat Pumps

Grant Engineering (UK) Ltd
Frankland Road, Blagrove, Swindon, Wiltshire SN5 8YG
t: +44 (0)1380 736920 f: +44 (0)1380 736991
e: info@grantuk.com w: www.grantuk.com



Models:	Outdoor Unit:	Aerona HPR29012
	Indoor Unit:	None
Air-to-water heat pump		<u>Yes</u>
Brine-to-water heat pump		<u>No</u>
Low temperature heat pump		<u>Ye</u> s
Equipped with a supplementary heater		<u>No</u>
Heat Pump Combination Heater		No
Parameters shall be declared for		low-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	ltem	Symbol	Value	Unit
Rated Heat Output (*)	Prated	11.2	kW	Seasonal space heating energy efficiency	ηs	190	%
Declared capacity for heating fo Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
Ti = -7°C	Pdh	10.47	kW	Tj = -7°C	COPd	3.12	1
Degradation co-efficient (**)	Cdh	0.90	-				
Ti = +2°C	Pdh	7.18	kW	Tj = +2°C	COPd	4.58	
Degradation co-efficient (**)	Cdh	0.90	-	, , , , , , , , , , , , , , , , , , , ,			
Ti = +7°C	Pdh	4.56	kW	Tj = +7°C	COPd	6.66	
Degradation co-efficient (**)	Cdh	0.90	-	,			
Ti = +12°C	Pdh	3.40	kW	Tj = +12°C	COPd	9.01	
Degradation co-efficient (**)	Cdh	0.90	-	,			
Ti = bivalent temperature	Pdh	11.12	kW	Ti = bivalent temperature	COPd	3.01	
Tj = operation limit	Pdh	10.86	kW	Ti = operation limit temperature	COPd	2.89	
temperature	D. II		134/	T: 4500 ("TOL 0000)	0001	_	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd		
Bivalent temperature	Tbiv	-9		Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	other than	active mo	de	Supplementary Heater			
Off Mode	Poff	0.007	kW	Rate heat output	P _{sup}	0.320	kW
Thermostat-off mode	Рто	0.027	kW		1 545		
Standby mode	P _{SB}	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	Рск	0.021	kW	Type or orrergy mpan			
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m³/h
Sound power level indoors/outdoors	L _{WA}	/49	dBA				
Annual Energy consumption	Q _{HE}	4803	kWh				
For heat pump combination heater				Water heating energy efficiency	ηwh		%
Declared load profile		NA					
Daily electricity consumption	Qelec		kW/h				
Annual electricity consumption	AEC		kW/h				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG



^(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Models:	Outdoor Unit:	Aerona HPR29012
	Indoor Unit:	<u>None</u>
Air-to-water heat pump		<u>Yes</u>
Brine-to-water heat pump		<u>No</u>
Low temperature heat pump		<u>No</u>
Equipped with a supplementary heater		<u>No</u>
Heat Pump Combination Heater		No
Parameters shall be declared for		Medium-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	11.2	kW	Seasonal space heating energy efficiency	ης	150	%
	Declared capacity for heating for part load at indoor			Declared coefficient of performance			
Temperature 20°C and outdoor temperature Tj				part load at indoor temperature 20	°C and outdoo	r temperatur	e Tj
Tj = -7°C	Pdh	10.43	kW	Tj = -7°C	COPd	2.32	
Degradation co-efficient (**)	Cdh	0.90	-				
Tj = +2°C	Pdh	6.56	kW	Tj = +2°C	COPd	3.76	
Degradation co-efficient (**)	Cdh	0.90	-				
Tj = +7°C	Pdh	4.57	kW	Tj = +7°C	COPd	5.06	
Degradation co-efficient (**)	Cdh	0.90	-				
Tj = +12°C	Pdh	3.20	kW	Tj = +12°C	COPd	6.83	
Degradation co-efficient (**)	Cdh	0.90	-				
Tj = bivalent temperature	Pdh	10.81	kW	Tj = bivalent temperature	COPd	2.23	
Tj = operation limit temperature	Pdh	10.58	kW	Tj = operation limit temperature	COPd	2.15	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-9	°C	Operation limit temperature	TOL	-10	°C
		•	•	Heating water operating limit temperature	WTOL	60	°C
Dower consumption in modes	othor thon	aativa ma	40	Cumplementary Heater			
Power consumption in modes Off Mode				Supplementary Heater	T n	0.500	1444
- · · · · · · · · · · · · · · · · · · ·	Poff	0.007	kW	Rate heat output	P _{sup}	0.580	kW
Thermostat-off mode	Рто	0.027	kW kW	Time of an army innut	Т	Electric	
Standby mode	P _{SB}	0.007	kW	Type of energy input		Electric	
Crankcase heater mode	Рск	0.021	KVV				
Other items					_		
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m³/h
Sound power level indoors/outdoors	L _{WA}	/52	dBA				
Annual Energy consumption	Q _{HE}	6069	kWh				
For host numn combination haster				Water heating analy official	l musik	123.1	0/
For heat pump combination heater Declared load profile		Large	I -	Water heating energy efficiency	ηwh		% °C
Daily electricity consumption	Qelec	4.04	kWh	Reference Hot Water	Θ' _{WH}	55.42	C
Annual electricity consumption	AEC	831.6	kWh/a				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG



^(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly

This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer.

Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it still remains contaminated by the refrigerant.

Neil Sawers Technical Manager

Grant heat pump fiche HPR29012 V1.7 15/01/2025

