# Product fiche relating to: The Eco Design for Energy Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019

**Air Source Heat Pumps** 

Grant Engineering (UK) Ltd
Frankland Road, Blagrove, Swindon, Wiltshire SN5 8YG
t: +44 (0)1380 736920 f: +44 (0)1380 736991
e: info@grantuk.com w: www.grantuk.com



Models:	Outdoor Unit:	Aerona <sup>3</sup> HPID10R32
	Indoor Unit:	None
Air-to-water heat pump		<u>Yes</u>
Brine-to-water heat pump		<u>No</u>
Low temperature heat pump		<u>Ye</u> s
Equipped with a supplementary heater		<u>No</u>
Heat Pump Combination Heater		No
Parameters shall be declared for		low-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	9.2	kW	Seasonal space heating energy efficiency	ηs	206.6	%
Declared capacity for heating fo Temperature 20°C and outdoor				Declared coefficient of performance part load at indoor temperature 20			
Ti = -7°C	Pdh	9.03	kW	Tj = -7°C	COPd	3.30	1
Degradation co-efficient (**)	Cdh	0.99	-				
Ti = +2°C	Pdh	5.29	kW	Tj = +2°C	COPd	5.96	
Degradation co-efficient (**)	Cdh	0.99	-				
Ti = +7°C	Pdh	3.40	kW	Tj = +7°C	COPd	7.80	
Degradation co-efficient (**)	Cdh	0.99	-				
Ti = +12°C	Pdh	3.70	kW	Tj = +12°C	COPd	9.20	
Degradation co-efficient (**)	Cdh	0.99	-	.,	00.0	0.20	
Ti = bivalent temperature	Pdh	7.99	kW	Tj = bivalent temperature	COPd	3.11	
Tj = operation limit	Pdh	5.90	kW	Tj = operation limit temperature	COPd	2.74	
temperature		5.90		, ,			
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-8		Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	other than	active mo	de	Supplementary Heater			
Off Mode	Poff	0.10	kW	Rate heat output	P <sub>sup</sub>	3.30	kW
Thermostat-off mode	Рто	0.04	kW	Trace most output	- oup	0.00	1111
Standby mode	PsB	0.10	kW	Type of energy input	Electric		
Crankcase heater mode	Рск	0.00	kW	Type or energy input			
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	2664	m³/h
Sound power level	L <sub>WA</sub>		dBA	Tated allilow fate, outdoors		2004	111711
indoors/outdoors		43/64					
Annual Energy consumption	Q <sub>HE</sub>	3628	kWh				
For heat pump combination heater				Water heating energy efficiency	ηwh		%
Declared load profile		NA		U U			
Daily electricity consumption	Qelec		kW/h				
Annual electricity consumption	AEC		kW/h				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG

(\*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Models:	Outdoor Unit:	Aerona <sup>3</sup> HPID10R32
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		<u>No</u>
Low temperature heat pump		<u>No</u>
Equipped with a supplementary heater		<u>No</u>
Heat Pump Combination Heater		No
Parameters shall be declared for		Medium-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	8.7	kW	Seasonal space heating energy efficiency	ηs	138.4	%
Declared capacity for heating fo				Declared coefficient of performance			
Temperature 20°C and outdoor	temperature	Tj		part load at indoor temperature 20	°C and outdoo	r temperatur	e Tj
Tj = -7°C	Pdh	8.16	kW	Tj = -7°C	COPd	2.29	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +2°C	Pdh	5.07	kW	Tj = +2°C	COPd	3.53	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +7°C	Pdh	3.40	kW	Tj = +7°C	COPd	5.41	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12°C	Pdh	3.95	kW	Tj = +12°C	COPd	8.45	
Degradation co-efficient (**)	Cdh	0.99	-	•			
Tj = bivalent temperature	Pdh	7.36	kW	Tj = bivalent temperature	COPd	2.14	
Tj = operation limit temperature	Pdh	5.77	kW	Tj = operation limit temperature	COPd	1.85	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-8	°C	Operation limit temperature	TOL	-10	°C
	1	-		Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes	other then	aativa ma	do	Supplementary Heater			
Off Mode				Supplementary Heater	I D	1000	13.07
	Poff	0.10	kW	Rate heat output	P <sub>sup</sub>	2.93	kW
Thermostat-off mode	Рто	0.04	kW	Towns of an army innert	Electric		
Standby mode	P <sub>SB</sub>	0.10	kW	Type of energy input	Electric		
Crankcase heater mode	Рск	0.00	kW				
Other items			•		_		
Capacity control	Variable			Rated airflow rate, outdoors	-	2664	m³/h
Sound power level indoors/outdoors	L <sub>WA</sub>	43/64	dBA				
Annual Energy consumption	Q <sub>HE</sub>	5085	kWh				
For heat pump combination heater				Water heating energy efficiency	ηwh	99.6	%
Declared load profile	-	L	-	Reference Hot Water	Θ' <sub>WH</sub>	51.6	°C
Daily electricity consumption	Qelec	4.85	kWh		- vvii		
Annual electricity consumption	AEC	1027.94	kWh/a				

Contact Details: Grant Engineering (UK) Ltd, Frankland Road, Blagrove, Swindon SN5 8YG



<sup>(\*)</sup> For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

# **End of Life Information – Air Source Heat Pumps**

#### General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

### **Disassembly**

This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer.

Under no circumstances should the refrigerant be released into the atmosphere.

### Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

## Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it still remains contaminated by the refrigerant.

Neil Sawers Technical Manager

Grant heat pump fiche. V2.0 15/01/2025

